

Paper IJEEE

by Handry K

Submission date: 23-Feb-2024 12:25PM (UTC+0700)

Submission ID: 2292603194

File name: Paper_SST_ijeee_r1.docx (2.78M)

Word count: 4599

Character count: 22555

Original Article

Power Flow Analysis of On-Grid Photovoltaic Generation Using A Solid-State Transformer

Hanny H. Tumbelaka¹, Handry Khoswanto², Thiang³, Stephanus A. Ananda⁴

^{1,2,3} Electrical Engineering Department, Petra Christian University, Indonesia.

⁴ Informatic Department, Petra Christian University, Indonesia.

¹Corresponding Author: thiang@petra.ac.id

Received:

Revised:

Accepted:

Published: (Size9)

Abstract - This paper describes the power flow of a grid-connected PV system utilizing a solid-state transformer (SST). The SST system comprises a DC-AC converter, an isolated high-frequency step-up transformer, a bridge rectifier, and a Voltage Source Inverter (VSI). The DC-AC converter transforms the PV panel output voltage into a 5-kHz three-level square wave, where its pulse width regulates the PV load lines to generate power. The VSI delivers the PV power to the single-phase grid employing a grid current controller and a DC bus voltage controller. Computer simulation results verify the system's effectiveness in controlling the power flow from PV panel through SST to the load and the grid while maintaining the grid current to be sinusoidal with a unity power factor, regardless of the presence of sunlight.

Keywords - Solid State Transformer, Grid-Connected PV, Voltage Source Inverter (VSI), Three-level Square Wave.

1. Introduction

Photovoltaic (PV) panels are commonly installed in both off-grid and on-grid configurations. In off-grid installation, electrical energy from the PV panel is only supplied to electrical loads and batteries as energy storage. Off-grid installation is suitable for remote areas. In some cases, the off-grid PV system works as a backup power source during power outages. In contrast, in on-grid installation, electrical energy that comes from the PV panel can be delivered to the grid as well as to electrical loads. The on-grid PV system does not need batteries or additional energy storage, making them cost-efficient and easy to maintain. The grid acts as a virtual storage system that allows sending or receiving electric power when needed. For the on-grid PV system, a grid-tie inverter (GTI) is generally required. The inverter converts a DC quantity into an AC quantity and can be synchronized to the grid [1][2].

The on-grid PV system has to be compatible with the grid. A potential issue with GTI arises because of the mismatch voltage between PV panel output voltage and grid voltage. The voltage difference can be adjusted with a transformer on the AC side [3] or a boost converter on the DC side [4]. In addition, The PV panel usually needs galvanic isolation from the grid for safety and signal integrity reasons. The isolation can also be handled using a transformer. Typically, the existing transformer works at the standard grid frequency (50/60) Hz and has a large weight and size.

Nowadays, solid-state transformers (SST) have been developed and used for many applications generally in distribution networks that connect the grid to the AC loads. SST is an AC-AC converter that combines a high-frequency transformer and power electronics converters [5][6][7]. The high-frequency transformer has a smaller weight and size than the conventional transformer (50/60 Hz). SST usually substitutes the conventional transformer [8][9], where the medium voltage (20 kV) is stepped down to the low voltage (220/380 V) to meet customer equipment specifications. Several SST configurations are shown in Figure 1.




Fig. 1 Configurations of SST a) single stage, b) and c) two stages, d) three stages [6]

Therefore, it is necessary to replace GTI with SST. SST will be used to connect the grid to the DC source, the PV panel. SST also transmits the PV power to the grid. Several researches have been conducted on the application of SST for the on-grid PV system. In [10], an additional bidirectional buck-boost converter is used to get the PV power. Another system [11] employs the SST topology featuring multilevel



H-bridge for LV inverters and MV rectifiers and inverters. This paper presents an innovative SST configuration suitable for the on-grid PV system. Instead of adding circuits and controllers, an innovative approach involves simplifying the SST configuration for ease of operation and expansion.

It is necessary to examine the power flow across PV panel, load and grid via SST in order to ensure this system works effectively. This analysis includes active and reactive power, comprising average and oscillating components. The analysis covers power flow at various loads and PV panel conditions, regardless of the presence of sunlight.

2. On-Grid PV Configuration

The chosen configuration for SST, as shown in Figure 1, is 1(d). It has three stages. Because the PV panel generates DC electricity, the AC-DC converter in the initial stage is removed. The PV panel is directly attached to the second stage, a DC-DC converter and this stage is named as Stage A. Stage A consists of three parts, i.e., a DC-AC converter, an isolated high-frequency transformer, and an AC-DC converter. Then, the Stage A output is connected to a DC-AC converter, denoted as Stage B, which is a Voltage Source Inverter (VSI). The VSI interfaces the Stage A output to the power grid. Hence, a series circuit of Stage A and Stage B delivers electrical power from PV panel to power grid and load. Figure 2 illustrates the implementation of the on-grid PV system using SST.




Fig. 2 Diagram of the grid-connected PV system

2.1. Solid State Transformer (SST)

The first component of Stage A is the DC-AC converter, which generates the high-frequency AC voltage from the PV panel's DC output voltage since the transformer works at a high frequency. The converter consists of four transistors configured as an H-bridge. Switching of four transistors is controlled by using a microcontroller (DC-AC Controller). The switching operation can also drive the PV panel to generate maximum power. A Simple concept algorithm used for this controller is shown in Figure 3. The microcontroller controls the switching time of the right and left legs of the H-bridge to produce square waves with a duty ratio of 50%. The

square wave generated by each leg is phase-shifted by the displacement angle (α). As a result, the output voltage of the bridge will be a three-level AC square wave (Figure 4) with a pulse width of $180^\circ - \alpha$. The angle α determines the root mean square (*rms*) value of the square wave voltage as given in Equation 1. The PV panel output detects the *rms* value which in turn dictates the load lines (operating points) of the PV panel. Figure 5 shows the load lines of the PV panel.

$$V_{sq-rms} = V_{dc} \sqrt{\frac{\pi - \alpha}{\pi}} \quad (1)$$




Fig. 3 Simple algorithm for controlling switching time




Fig. 4 Three-level square wave with a displacement angle α

The isolated high-frequency transformer as the second part of Stage A works at a frequency of 5 kHz. It is a two-winding step-up transformer, with the primary winding being supplied by the DC-AC converter, and the secondary winding directed to the AC-DC converter. Its winding ratio is adjusted to match the PV panel output voltage level (≈ 35 V) to the VSI input voltage level (DC Bus voltage ≈ 350 V). The transformer also provides galvanic isolation between the PV panel and the grid.




Fig. 5 Load lines of the PV panel [12]

The last part is an uncontrolled rectifier, which employs four diodes as an H-bridge. The rectifier converts a high-frequency AC voltage from the secondary side of the transformer to the DC bus voltage (V_o) of Stage B. The diode bridge also prevents power reversal from the grid to the PV panel. The power flow becomes unidirectional from the PV panels to the grid as well as the load. A power capacitor is installed at the DC bus as an energy storage to reduce the voltage ripple.

2.2. The Grid-connected Voltage Source Inverter

In Stage B, the Voltage Source Inverter (VSI) uses four transistors as an H-bridge, with an inductor L_{inv} at the AC side, and connects the output of Stage A to the single-phase power grid. Different from the previous DC-AC converter in Stage A, in the VSI, the diagonally opposite transistors from the two legs are switched as switch pairs to produce a bipolar pulse width modulation (PWM) square wave.

The VSI has a current controller and a voltage controller [1][2]. The current controller has a current sensor on the grid side and senses the grid current. The output signal of the sensor is compared to the sinusoidal reference current (i_{ref}). The result is a high-frequency PWM signal to switch the transistors. By locating current sensor on the grid side, the grid current controller can drive the grid current to be the same as the sinusoidal reference current (i_{ref}). This reference current is synchronized to the grid voltage and given by:

$$i_{ref}(t) = k v_{grid-1}(t) \quad (2)$$

where v_{grid-1} is the fundamental component of the grid voltage and k is the PI controller output. Consequently, the VSI automatically produces the current (i_{inv}) according to:

$$i_{grid}(t) = i_{inv}(t) + i_{load}(t) \quad (3)$$

The objective of the voltage controller is to maintain a constant DC bus voltage at its designated reference value. A voltage sensor is positioned at the DC bus to sense its voltage. The sensor output signal is compared to the DC bus reference voltage. The reference value should be greater than the amplitude of the grid voltage wave. Then, the error is controlled by a simple PI controller and produces a gain k . This gain k determines the amplitude of i_{ref} as written in Equation 2. This is an effective way of determining the required amplitude of grid active current since any active power mismatch among the grid, the load, and the VSI would result in the necessary corrections and regulate the DC bus voltage. The response speed of the voltage controller is considerably slower than that of the grid current controller, leading to the decoupling of the grid current controller and the voltage controller. Figure 6 reveals that the PI controller functions correctly. The DC bus voltage (V_o) is kept constant at 350 V.




Fig. 6 DC Bus Voltage (V_o)

3. Power Flow

3.1. The PV Power

The power that is generated by the PV panel depends on the solar irradiance levels. Increased irradiance corresponds to higher PV output power. Moreover, at a specific irradiance level, the output power of the PV panel depends on its load lines illustrated in Figure 5. As discussed earlier, changing the displacement angle (α) leads to changes in the *rms* value of the square wave voltage. The *rms* value determines the load lines (operating points) of the PV panel. Hence, the PV panel output notices varying voltages which then affects its output power. The maximum power occurs when the voltage equals V_{MPP} .

3.2. The SST Power

For ideal converter conditions, the input power is equal to the output power. The converter transmits the received power to its output. In actual conditions, the significant losses

in the converter occur in the form of switching losses, the amount of which depends on the switching frequency. Similarly, for ideal transformer conditions, the input power equals the output power. In actual conditions, there are core loss and copper loss. In SST, there is no energy conversion. The converter and transformer only transmit electric power from the PV panel. As discussed earlier, the power flow is unidirectional to the grid due to diodes in the rectifier.

3.3. The Grid Power

For a single-phase power grid, $v(t) = V \sin \omega t$, and $i(t) = I \sin (\omega t - \varphi)$. The instantaneous power will be [13][14]:

$$p(t) = v(t) i(t) = VI \cos \varphi (1 - \cos 2\omega t) - VI \sin \varphi \sin 2\omega t \quad (4)$$

$$p(t) = P (1 - \cos 2\omega t) - Q \sin 2\omega t \quad (5)$$

The instantaneous power $p(t)$ has two components. The first component oscillates at twice the line frequency and has an average value of $P = VI \cos \varphi$, denoted as active power. The second component also oscillates at twice the line frequency with an amplitude equal to $Q = VI \sin \varphi$, named reactive power. It has zero average value. The active power (P) can also be calculated as follows:

$$P = \frac{1}{T} \int_0^T v(t) i(t) dt \quad (6)$$

Due to the grid current controller, $i_{grid}(t) = I_{grid} \sin \omega t$. The grid current is sinusoidal and has same phase with the grid voltage according to Equation 2. Since $\varphi = 0$, then $Q = 0$ and $p(t)$ in Equation 5 becomes:

$$p_{grid}(t) = P (1 - \cos 2\omega t) \quad (7)$$

The load current $i_{load}(t) = I_{load} \sin (\omega t - \varphi)$. According to Equation 3, the output current of the VSI (i_{inv}) is given by:

$$i_{inv}(t) = I_{inv} (\cos \varphi \sin \omega t - \sin \varphi \cos \omega t) \quad (8)$$

It can be seen that the VSI current consists of two components which are active current and reactive current. The two currents are orthogonal and correspond to active power and reactive power respectively. The amount of active power is determined by the PV output power. Hence, the grid current control regulates the power flow of the grid, the VSI, and the load.

4. Simulation Results and Discussions

The circuit in Figure 2 is simulated using PSIM simulator to prove the concept and to analyze the power flow. The circuit proceeds under steady-state conditions. The parameters used for the simulation are seen in Table 1.

Table 1. Circuit Parameters

Parameters	Value
V_{g-rms}	220 V
Z_{grid}	0.02 Ω , 0.3 mH
L_{inv}	0.25 Ω , 1.51 mH
DC-bus Capacitor	6600 μ F
Transformer ratio	1: 13
PV V_{mpp}	35.6 V
PV I_{mpp}	28.1 A

4.1. The PV Output Power

To analyze the PV output power, the simulation focuses on the performance of the displacement angle control strategy. The circuit in Figure 2 is tested under irradiance of 1000 W/m².

Figure 7 shows the output voltage and current of the PV panel at maximum power. $I_{pv} = 28.02$ A, $V_{pv} = 35.68$ V, $P_{pv}(\text{max}) = 999.8$ W. The values of I_{pv} and V_{pv} are matched with the parameters specified in Table I for the PV panel. To achieve the PV maximum power, the displacement angle (α) must be 29°. Figure 8 shows the output voltage of the DC-AC converter presenting a 5-kHz three-level square wave with a pulse width of 151°. $V_{rms} = 32.74$ V. This voltage is fed to the transformer's primary winding. The transformer's secondary voltage increases to 350 V (*rms*) due to its winding ratio, with the amplitude held equal to the DC bus voltage.




Fig. 7 PV output voltage and current for $\alpha = 29^\circ$




Fig. 8 Transformer primary (top) and secondary (bottom) voltages for $\alpha = 29^\circ$

If the displacement angle (α) is changed to 60° , the pulse width of the square wave becomes 120° . Then, the *rms* value of the output voltage of the DC-AC converter, which is the same as the transformer's primary voltage (Figure 10) changes to 31.14 V. As a result, the PV output voltage and current also change (Figure 9). $I_{pv} = 25.31$ A, $V_{pv} = 37.92$ V, $P_{pv} = 959.4$ W. This change indicates a decline in the PV output power compared to its maximum value.




Fig. 9 PV output voltage and current for $\alpha = 60^\circ$




Fig. 10 Transformer primary voltage for $\alpha = 60^\circ$

For a similar case, Figure 11 displays the PV output voltage and current with an angle of 10° . The pulse width of the square wave equals 170° . $I_{pv} = 28.41$ A, $V_{pv} = 35.12$ V, $P_{pv} = 997.76$ W. It can be seen that the PV output power is also less than its maximum value. This is because the *rms* value of the output voltage of the DC-AC converter, which is the same as the transformer's primary voltage (Figure 12) for $\alpha = 10^\circ$ becomes 34.29 V.




Fig. 11 PV output voltage and current for $\alpha = 10^\circ$




Fig. 12 Transformer primary voltage for $\alpha = 10^\circ$

Table 2. Displacement Angle Effects

α	$V_{out\ DC-AC\ converter\ (V_{rms})}$	$I_{pv}\ (A)$	$V_{pv}\ (V)$	$P_{pv}\ (W)$
10°	34.29	28.41	35.12	997.76
29°	32.74	28.02	35.68	999.81
60°	31.14	25.31	37.92	959.41

The PV output power, the output voltage of the DC-AC converter, and the displacement angle (α) discussed before are summarized in Table 2. The controller will adjust the converter switching time according to the angle. The angle as well as the pulse width of the square wave determines the *rms* value of the DC-AC converter output voltage. Increasing the angle leads to a decrease in the *rms* value of the voltage supplied to the high-frequency transformer and the PV output current, but increases the PV output voltage. However, PV output power will go up and down like a curve, with a maximum power point at $\alpha = 29^\circ$. Hence, the output power (load lines) of the PV panel corresponds to the displacement angle (α). Moreover, the transformer operates at variable voltage, which results in delivering variable power. The amount of power passing through Stages A and B depends on the available power from the PV panel.

4.2. The VSI and The Grid Power

To evaluate the power flow among the grid, the VSI, and the linear (*RL*) load, the PV panel is operated at maximum power ($P_{pv} = 999.81$ W). The displacement angle (α) equals 29° . The VSI output power (P_{inv}) comes from the PV output power passing through Stages A and B in series.

In the first case, the inverter (VSI) output power, in terms of active power, is greater than the load power. Figure 13 displays the grid voltage (top) and the currents of the grid, the VSI, and the load (bottom). Their *rms* values: $I_{grid} = 1.79$ A, $I_{inv} = 4.62$ A, $I_{load} = 2.91$ A. Due to the grid current controller, Figure 13 also shows that the grid current waveform is forced to be the same as the sinusoidal reference current (i_{ref}). The grid current has the same zero crossing points as the grid

voltage. Moreover, the VSI automatically produces a reactive current, as per Equation 8, to compensate for the reactive current of the load.

Figure 14 illustrates the grid power, the VSI power, and the load power. They oscillate at a frequency of 100 Hz. Based on Equations 5 and 6, their average values (active power): $P_{grid} = -390.21$ W, $P_{inv} = 977.66$ W, and $P_{load} = 587.45$ W. The grid power follows Equation 7 but flows in the reverse direction.




Fig. 13 The grid voltage (top) and the currents of the grid, the VSI, and the load (bottom) for $P_{inv} > P_{load}$




Fig. 14 The VSI power, the load power (top), and the grid power (bottom) for $P_{inv} > P_{load}$




Fig. 15 The PI controller output signal (top) and i_{ref} (bottom) for $P_{inv} > P_{load}$

Since $P_{inv} > P_{load}$, the excess active power from the VSI is delivered to the grid. It is shown that the grid current is out of phase with the grid voltage resulting in negative active power. The direction of the grid current as well as the active power is from the VSI to the grid.

Figure 15 shows the PI controller output signal (top) and i_{ref} (bottom). The sinusoidal reference current (i_{ref}) is obtained from Equation 2. The PI controller output (k) dictates its amplitude. The average value of k is negative (-2.51). As a result, the phase difference between the grid voltage and the grid current is 180° .

In the second case, the inverter (VSI) output power, in terms of active power, is less than the load power. Figure 16 displays the grid voltage (top) and the currents of the grid, the VSI, and the load (bottom). Their rms values: $I_{grid} = 3.79$ A, $I_{inv} = 4.95$ A, $I_{load} = 8.53$ A. Figure 16 also shows that the grid current is sinusoidal with a unity power factor due to the grid current control. The correlation of the grid current, the VSI current, and the load current agrees with Equation 3. The direction of the grid current is from the grid to the load.

Figure 17 demonstrates the grid power, the VSI power, and the load power for the second case. Their frequency is 100 Hz. From Equations 5 and 6, their average values (active power): $P_{grid} = 824.36$ W, $P_{inv} = 977.49$ W, and $P_{load} = 1801.85$ W.




Fig. 16 The grid voltage (top) and the currents of the grid, the VSI, and the load (bottom) for $P_{inv} < P_{load}$




Fig. 17 The VSI power, the load power (top), and the grid power (bottom) for $P_{inv} < P_{load}$

Since $P_{inv} < P_{load}$, the VSI output active power is not sufficient for the load power consumption. Then, the power deficit to supply the load is drawn from the grid. The grid power is positive and conforms with Equation 7. Figure 17 also shows that the VSI power comprises both active and reactive components. The active power comes from the PV power and is supplied to the load. The reactive power

corresponds to the presence of a reactive current component, as per Equation 8. The reactive power is used to compensate for the load reactive power.

Figure 18 shows the PI controller output signal (top) and i_{ref} (bottom). The average value of k has changed to 5.37. Hence, any mismatch in the system power flow will regulate the DC bus voltage and change the value of k which adjusts the grid current amplitude. Because the value of k is positive, there is no phase difference between the grid voltage and the grid current.




Fig. 18 The PI controller output signal (top) and i_{ref} (bottom) for $P_{inv} < P_{load}$

The SST system still can function at night when the irradiance is very low. Figure 19 reveals the PV output voltage and current. There is no significant current flowing out from the PV panel. As a result, no electric power is delivered via the series of Stage A and Stage B to the load and the grid. The grid fully supplies the load active power.




Fig. 19 PV output voltage and current for very low irradiance

However, the VSI still generates current. Figure 20 displays the grid voltage (top) and the currents of the grid, the VSI, and the load (bottom). Their rms values: $I_{grid} = 2.72$ A, $I_{inv} = 1.12$ A, $I_{load} = 2.91$ A. The grid current is similar to the load current. Referring to Equation 8, when the active current is close to zero, then the VSI only generates the reactive current to compensate for the load reactive current. The phase angle between the grid voltage and the VSI current is around 90° . Figure 21 shows the grid power, the VSI power, and the load power. The average value of the VSI power is close to zero because there is no PV power.

Figure 22 shows the PI controller output signal (top) and i_{ref} (bottom). For very low irradiance, the average value of k has changed to 3.81. The value of k is positive, so that no phase difference between the grid voltage and current.




Fig. 20 The grid voltage (top) and the currents of the grid, the VSI, and the load (bottom) for very low irradiance




Fig. 21 The VSI power, the load power (top), and the grid power (bottom) for very low irradiance




Fig. 18 The PI controller output signal (top) and i_{ref} (bottom) for very low irradiance

Table 3. Power Flow

	P_{grid} (W)	P_{inv} (W)	P_{load} (W)
$P_{inv} > P_{load}$	-390.22	977.66	587.45
$P_{inv} < P_{load}$	824.37	977.49	1801.85
$P_{pv} \approx 0$	588.98	-1.26	587.72

The grid active power, The VSI output active power, and the load active power discussed above are summarized in Table III. Table III also shows that there is no electric power from the grid flowing back to the VSI for both $P_{inv} < P_{load}$ and $P_{pv} \approx 0$. This is due to the diode rectifier in Stage A that prevents power reversal from the grid to the PV panel.

5. Conclusion

This paper explains the power flow of a single-phase grid-connected PV system using a modified solid-state transformer (SST), which connects the PV panel to the grid. SST consists of a DC-DC converter (Stage A) and a VSI (Stage B). The DC-DC converter consists of a DC-AC converter, a two-winding isolated high-frequency transformer, and an uncontrolled rectifier.

To send solar energy to the load and grid, there are two control strategies. The first control strategy uses the pulse width of the three-level square wave to determine the P_{load} lines (operating points). The square wave is supplied to the

primary winding of the high-frequency transformer. The transformer operates at variable voltage, which results in delivering variable power. For the second control strategy, the VSI has a grid current controller and a DC bus voltage controller to regulate the flow of electrical power from the grid, the VSI, and the load. All of the control strategies are decoupled so they can work independently.

Computer simulation results using PSIM prove that the SST system works very well. The PV power is delivered to the load and the grid via a series circuit of Stages A and B, while the grid current is sinusoidal and in phase with the grid voltage, regardless of the presence of sunlight or not.

Acknowledgments

The authors would like to thank The Ministry of Education, Culture, Research, and Technology, Indonesia for the research grant, and PT. Bambang Djaja, Transformer Manufacturer, Indonesia for providing a high-frequency transformer.

References

- [1] Tumbelaka, H. H., M. Miyatake, "Simple Integration of Three-phase Shunt Active Power Filter and Photovoltaic Generation System with Fibonacci-Search-Based MPPT," *Proceedings of IEEE Symposium on Industrial Electronics and Application (ISIEA)*, October 2010, Malaysia.
- [2] Tumbelaka, H. H., and Borle, L. J., "Harmonic Mitigation Using a Polarized Ramp-time Current-Controlled Inverter" *Telkomnika*, vol. 8, no. 3, pp. 235-244, 2010.
- [3] Tumbelaka, H. H., E. Muljadi, and W. Gao, "The Impact of Transformer Winding Connections of a Grid-Connected PV on Voltage Quality Improvement," *International Journal of Renewable Energy Research*, vol. 8, no. 1, pp. 7-14, March 2018.
- [4] D. -Y. Jung, Y. -H. Ji, S. -H. Park, Y. -C. Jung and C. -Y. Won, "Interleaved Soft-Switching Boost Converter for Photovoltaic Power-Generation System," *IEEE Transactions on Power Electronics*, vol. 26, no. 4, pp. 1137-1145, April 2011
- [5] Shadfar, H., M. G. Pashakolaei, A. A. Foroud, "Solid-state Transformers: An Overview of The Concept, Topology, and Its Applications in The Smart Grid," *International Transactions on Electrical Energy System*, vol. 31, no. 9, 2021.
- [6] M. A. Hannan, et al., "State of the Art of Solid-State Transformers: Advanced Topologies, Implementation Issues, Recent Progress, and Improvements", *IEEE Access*, vol. 8, 2020.
- [7] Sudhoff, S. D., W. Lafayette, "Solid State Transformer". *US Patent No. 5,943,229*, 1999.
- [8] Saleh, S. A. M., et al., "Solid-State Transformers for Distribution Systems-Part I: Technology and Construction," *IEEE Transactions on Industry Applications*, vol. 55, no. 5, pp. 4524-4535, 2019.
- [9] Silva, R. L. D., et al., "Solid-State Transformer for Power Distribution Grid Based on a Hybrid Switched-Capacitor LLC-SRC Converter: Analysis, Design, and Experimentation". *IEEE Access*, vol. 8, 2020.
- [10] Madhu, K., Reddy, V. S. K., "Grid-Connected PV-Wind-Battery Based Multi-Input Transformer Coupled Bidirectional DC-DC Converter with Multilevel Inverter Fed AC Load," *International Journal of Scientific Engineering and Technology Research*, vol. 06, no. 32, pp. 6588-6593, November 2017.
- [11] G. Brando, A. Dannier and R. Rizzo, "Power Electronic Transformer application to grid-connected photovoltaic systems," *International Conference on Clean Electrical Power*, Capri, Italy, pp. 685-690, 2009.
- [12] Ferdous, S. M., et al., "Design and Simulation of an Open Voltage Algorithm based Maximum Power Point Tracker for Battery Charging PV System," *7th International Conference on Electrical & Computer Engineering (ICECE)*, 2012.
- [13] Watanabe, E. H., et al., "New Concepts of Instantaneous Active and Reactive Powers in Electrical Systems in Generic Loads," *IEEE Transactions on Power Delivery*, vol. 8, no. 2, pp. 697-703, 1993
- [14] F. Z. Peng, L. M. Tolbert and Zhaoming Qian, "Definitions and compensation of non-active current in power systems," *2002 IEEE 33rd Annual IEEE Power Electronics Specialists Conference. Proceedings*, Cairns, QLD, Australia, 2002, pp. 1779-1784 vol.4

Paper IJEEE

ORIGINALITY REPORT

7 %

SIMILARITY INDEX

7 %

INTERNET SOURCES

5 %

PUBLICATIONS

3 %

STUDENT PAPERS

PRIMARY SOURCES

1

www.davidpublisher.com

Internet Source

1 %

2

Submitted to Alliance University

Student Paper

1 %

3

www.tdx.cat

Internet Source

1 %

4

Submitted to universititeknologimara

Student Paper

1 %

5

schematicsforfree.com

Internet Source

1 %

6

dl.lib.uom.lk

Internet Source

1 %

7

repository.lib.ncsu.edu

Internet Source

1 %

8

Ahmet Aktaş, Yağmur Kirçiçek. "The Role and Importance of Energy Storage Systems in Solar Hybrid Applications", Elsevier BV, 2021

Publication

1 %

findresearcher.sdu.dk

Exclude quotes On
Exclude bibliography On

Exclude matches < 1%